

Jefferson Elementary

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
1A Hallway Bubbler	1/15/2025 06:05	1/21/2025 10:16	70333156001	Lead	<1.0
1B Hallway Bottle Fill	1/15/2025 06:06	1/21/2025 10:18	70333156002	Lead	<1.0
4 Rm 210 Sink	1/15/2025 06:02	1/21/2025 10:20	70333156003	Lead	1.6
9 Rm 212 Sink	1/15/2025 06:00	1/21/2025 10:24	70333156004	Lead	2.3
10- Back Library Sink	1/15/2025 05:59	1/21/2025 10:26	70333156005	Lead	<1.0
11 - Rm 214 Sink	1/15/2025 05:58	1/21/2025 10:27	70333156006	Lead	<1.0
12A - Rm 301 Bubbler	1/15/2025 05:56	1/21/2025 10:32	70333156007	Lead	<1.0
12B - Rm 301 Sink	1/15/2025 05:57	1/21/2025 10:36	70333156008	Lead	<1.0
13A- Rm 303 Bubbler	1/15/2025 05:54	1/21/2025 10:44	70333156009	Lead	<1.0
13B- Rm 303 Sink	1/15/2025 05:55	1/21/2025 10:45	70333156010	Lead	1.6
14A- Rm 305 Bubbler	1/15/2025 05:52	1/21/2025 10:47	70333156011	Lead	<1.0
14B- Rm 305 Sink	1/15/2025 05:53	1/21/2025 10:48	70333156012	Lead	<1.0
15A Hallway Bubbler	1/15/2025 05:53	1/21/2025 10:50	70333156013	Lead	<1.0
15B- Hallway Bottle Fill	1/15/2025 05:54	1/21/2025 10:52	70333156014	Lead	<1.0
20- Nurse Exam Rm Sink	1/14/2025 07:30	1/21/2025 10:53	70333156015	Lead	<1.0
21 - Nurse Bathroom Sink	1/14/2025 07:31	1/21/2025 10:55	70333156016	Lead	<1.0
22A- Rm 404 Bubbler	1/14/2025 07:28	1/21/2025 10:56	70333156017	Lead	<1.0
22B- Rm 404 Sink	1/14/2025 07:29	1/21/2025 11:01	70333156018	Lead	<1.0
24A- Hallway Bubbler	1/14/2025 07:26	1/21/2025 11:03	70333156019	Lead	<1.0
24B- Hallway Bottle Fill	1/14/2025 07:27	1/21/2025 11:04	70333156020	Lead	<1.0
27A- Rm 406 Bubbler	1/14/2025 07:22	1/21/2025 11:06	70333156021	Lead	<1.0
27B- Rm 406 Sink	1/14/2025 07:23	1/21/2025 11:07	70333156022	Lead	<1.0
28A- Rm 405 Bubbler	1/14/2025 07:24	1/21/2025 11:09	70333156023	Lead	<1.0
28B- Rm 405 Sink	1/14/2025 07:25	1/21/2025 11:11	70333156024	Lead	<1.0
29A- Rm 407 Bubbler	1/14/2025 07:20	1/21/2025 11:12	70333156025	Lead	<1.0
29B- Rm 407 Sink	1/14/2025 07:19	1/21/2025 11:14	70333156026	Lead	<1.0
30A- Rm 409 Bubbler	1/14/2025 07:17	1/21/2025 11:21	70333156027	Lead	<1.0
30B- Rm 409 Sink	1/14/2025 07:16	1/21/2025 11:26	70333156028	Lead	<1.0
31A- Rm 410 Bubbler	1/14/2025 07:15	1/21/2025 11:30	70333156029	Lead	<1.0
31B- Rm 410 Sink	1/14/2025 07:14	1/21/2025 11:32	70333156030	Lead	<1.0
32A- Rm 411 Bubbler	1/14/2025 07:12	1/21/2025 11:33	70333156031	Lead	<1.0
32B- Rm 411 Sink	1/14/2025 07:11	1/21/2025 11:38	70333156032	Lead	<1.0
33A- Rm 412 Sink	1/14/2025 07:08	1/21/2025 11:40	70333156033	Lead	<1.0
33B- Rm 412 Bubbler	1/14/2025 07:09	1/21/2025 11:41	70333156034	Lead	<1.0
34A- Rm 413 Sink	1/14/2025 07:06	1/21/2025 11:43	70333156035	Lead	<1.0
34B- Rm 413 Bubbler	1/14/2025 07:07	1/21/2025 11:44	70333156036	Lead	<1.0
35A- Rm 414 Sink	1/14/2025 07:04	1/21/2025 11:46	70333156037	Lead	1.4
35B- Rm 414 Bubbler	1/14/2025 07:05	1/21/2025 11:47	70333156038	Lead	<1.0
36A- Rm 415 Sink	1/14/2025 07:02	1/21/2025 11:49	70333156039	Lead	<1.0
36B- Rm 415 Bubbler	1/14/2025 07:03	1/21/2025 11:51	70333156040	Lead	<1.0
37A- Rm 416 Sink	1/14/2025 07:00	1/21/2025 11:52	70333156041	Lead	<1.0
37B- Rm 416 Bubbler	1/14/2025 07:01	1/21/2025 11:57	70333156042	Lead	<1.0
38A- Rm 417 Sink	1/14/2025 06:58	1/21/2025 11:58	70333156043	Lead	1.5
38B- Rm 417 Bubbler	1/14/2025 06:59	1/21/2025 12:00	70333156044	Lead	<1.0
39A- Rm 418 Sink	1/14/2025 06:56	1/21/2025 12:02	70333156045	Lead	<1.0
39B- Rm 418 Bubbler	1/14/2025 06:57	1/21/2025 12:03	70333156046	Lead	<1.0
40A- Playroom Bubbler	1/15/2025 05:36	1/21/2025 12:08	70333156047	Lead	<1.0
40B- Playroom Bottle Fill	1/15/2025 05:37	1/21/2025 12:15	70333156048	Lead	<1.0
41- Kitchen Service Line	1/15/2025 05:47	1/21/2025 12:20	70333156049	Lead	<1.0
42L- Kettle Fill Left	1/15/2025 05:42	1/21/2025 12:21	70333156050	Lead	1.0
43R- Kitchen Kettle Right	1/15/2025 05:43	1/21/2025 12:23	70333156051	Lead	18.2
44- Kitchen Small Kettle	1/15/2025 05:41	1/21/2025 12:25	70333156052	Lead	1.3
46- Kitchen Ice Machine	1/15/2025 05:44	1/21/2025 12:26	70333156053	Lead	<1.0
47- Kitchen Sink	1/15/2025 05:48	1/21/2025 12:28	70333156054	Lead	2.0
53- Rm 249 Sink	1/15/2025 06:08	1/21/2025 12:29	70333156055	Lead	<1.0
56- Rm 225 Sink	1/15/2025 06:09	1/21/2025 12:34	70333156056	Lead	1.7
57- Rm 226 Sink	1/15/2025 06:10	1/21/2025 12:35	70333156057	Lead	2.2
58- Rm 227 Sink	1/15/2025 06:12	1/21/2025 12:37	70333156058	Lead	1.5
65A- Hallway Bubbler	1/15/2025 06:15	1/21/2025 12:39	70333156059	Lead	<1.0
65B- Hallway Bottle Fill	1/15/2025 06:16	1/21/2025 12:40	70333156060	Lead	<1.0
66- Rm 101 Sink	1/15/2025 06:17	1/21/2025 12:42	70333156061	Lead	1.5
67- Rm 103 Sink	1/15/2025 06:18	1/21/2025 12:43	70333156062	Lead	1.6
68- Rm 105 Sink	1/15/2025 06:26	1/21/2025 12:45	70333156063	Lead	1.0
69- Rm 107 Sink	1/15/2025 06:25	1/21/2025 12:47	70333156064	Lead	<1.0
70- Rm 108 Sink	1/15/2025 06:24	1/21/2025 12:48	70333156065	Lead	1.1
71- Rm 106 Sink	1/15/2025 06:21	1/21/2025 12:53	70333156066	Lead	1.4
72- Rm 104 Sink	1/15/2025 06:20	1/21/2025 12:57	70333156067	Lead	1.1
73- Rm 102 Sink	1/15/2025 06:19	1/21/2025 13:02	70333156068	Lead	1.3
76- Rm 229 Sink	1/15/2025 06:13	1/21/2025 13:06	70333156069	Lead	<1.0
77RM 234 Sink	1/15/2025 06:28	1/21/2025 13:11	70333156070	Lead	8.9
78- Rm 237 Sink	1/15/2025 06:29	1/23/2025 17:27	70333156071	Lead	3.5
79A- Hallway Bubbler	1/15/2025 06:32	1/23/2025 17:29	70333156072	Lead	<1.0
79B- Hallway Bottle Fill	1/15/2025 06:33	1/23/2025 17:31	70333156073	Lead	<1.0
80- Rm 238 Sink	1/15/2025 06:31	1/23/2025 17:32	70333156074	Lead	<1.0

NYSDOH Action Level for Lead in Schools of 5 ppb

Remedy

Date Remedy was Completed

Date Re tested

Sink Taken out of service 1/24/25 Will replace faucet and re test

TBD

1/27/2025

Do no drink signage

Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
2- Nurse	1/14/2025 06:02	1/24/2025 13:05	70333158001	Lead	<1.0	5	ug/L
3 Nurse Work Area	1/14/2025 06:01	1/24/2025 13:07	70333158002	Lead	<1.0	5	ug/L
4 Rm Main Office Sink	1/14/2025 06:03	1/24/2025 13:11	70333158003	Lead	<1.0	5	ug/L
6A Hallway Bubblers	1/14/2025 06:04	1/24/2025 13:16	70333158004	Lead	<1.0	5	ug/L
6B Hallway Bottle Fill	1/14/2025 06:05	1/24/2025 13:20	70333158005	Lead	<1.0	5	ug/L
11A Hallway Bubblers	1/14/2025 06:10	1/24/2025 13:25	70333158006	Lead	<1.0	5	ug/L
11B Hallway Bottle Fill	1/14/2025 06:11	1/24/2025 13:30	70333158007	Lead	<1.0	5	ug/L
18 Career Center Sink	1/14/2025 06:17	1/24/2025 13:31	70333158008	Lead	<1.0	5	ug/L
21A Cafe B Bubblers	1/14/2025 06:13	1/24/2025 13:33	70333158009	Lead	<1.0	5	ug/L
21B Cafe B Bottle Fill	1/14/2025 06:14	1/24/2025 13:34	70333158010	Lead	<1.0	5	ug/L
23A Cafe A Bubblers	1/14/2025 06:15	1/24/2025 13:36	70333158011	Lead	<1.0	5	ug/L
23B Cafe A Bottle Fill	1/14/2025 06:16	1/24/2025 13:38	70333158012	Lead	<1.0	5	ug/L
24 Faculty Rm Sink	1/14/2025 06:18	1/24/2025 13:39	70333158013	Lead	1.8	5	ug/L
25A Hallway Bubblers	1/14/2025 06:19	1/24/2025 13:41	70333158014	Lead	<1.0	5	ug/L
25B Hallway Bottle Fill	1/14/2025 06:20	1/24/2025 13:42	70333158015	Lead	<1.0	5	ug/L
26 Rm 115 Sink	1/14/2025 06:24	1/24/2025 13:44	70333158016	Lead	<1.0	5	ug/L
27 Rm 115 Sink	1/14/2025 06:25	1/24/2025 13:49	70333158017	Lead	<1.0	5	ug/L
28 Rm 115 Sink	1/14/2025 06:26	1/24/2025 13:50	70333158018	Lead	<1.0	5	ug/L
29 Rm 115 Sink	1/14/2025 06:27	1/24/2025 13:52	70333158019	Lead	<1.0	5	ug/L
30 Rm 115 Sink	1/14/2025 06:28	1/24/2025 13:53	70333158020	Lead	<1.0	5	ug/L
47A Hallway Bubblers	1/14/2025 06:31	1/24/2025 13:55	70333158021	Lead	<1.0	5	ug/L
47B Hallway Bottle Fill	1/14/2025 06:32	1/24/2025 13:57	70333158022	Lead	<1.0	5	ug/L
47C Hallway Bubblers	1/14/2025 06:33	1/24/2025 13:58	70333158023	Lead	<1.0	5	ug/L
48 Library Office	1/14/2025 06:35	1/24/2025 14:03	70333158024	Lead	<1.0	5	ug/L
75A 2nd Floor Bubblers	1/14/2025 06:07	1/24/2025 14:10	70333158025	Lead	<1.0	5	ug/L
75B 2nd Floor Bottle Fill	1/14/2025 06:08	1/24/2025 14:15	70333158026	Lead	<1.0	5	ug/L

Remedy

Date Remedy was Completed

Date Re tested

NYSDOH Action Level for Lead In Schools of 5 ppb

High School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
8A Hallway Bubbler	1/14/2025 05:57	1/24/2025 14:17	70333159001	Lead	<1.0	5	ug/L
8B Hallway Bottle Fill	1/14/2025 05:58	1/24/2025 14:18	70333159002	Lead	<1.0	5	ug/L
77 Gym 1 Storage Ice Machine	1/14/2025 05:47	1/24/2025 14:20	70333159003	Lead	<1.0	5	ug/L
83 Concession Sink	1/14/2025 05:45	1/24/2025 14:21	70333159004	Lead	3.6	5	ug/L
84A Gym Lobby Bubbler	1/14/2025 05:41	1/24/2025 14:26	70333159005	Lead	<1.0	5	ug/L
85B Gym Lobby Bottle Fill	1/14/2025 05:42	1/24/2025 14:28	70333159006	Lead	<1.0	5	ug/L
85C Gym Lobby Single Bubbler	1/14/2025 05:43	1/24/2025 14:29	70333159007	Lead	<1.0	5	ug/L
91A Hallway Bubbler	1/14/2025 05:33	1/24/2025 14:31	70333159008	Lead	<1.0	5	ug/L
96A Hallway Bubbler	1/14/2025 05:31	1/24/2025 14:33	70333159009	Lead	<1.0	5	ug/L
96B Hallway Bottle Fill	1/14/2025 05:32	1/24/2025 14:34	70333159010	Lead	<1.0	5	ug/L
101A Hallway Bubbler	1/14/2025 05:36	1/24/2025 14:36	70333159011	Lead	<1.0	5	ug/L
101B Hallway Bottle Fill	1/14/2025 05:37	1/24/2025 16:38	70333159012	Lead	<1.0	5	ug/L
102A Weight Room Bubbler	1/14/2025 05:38	1/24/2025 14:37	70333159013	Lead	<1.0	5	ug/L
102B Weight Room Bottle Fill	1/14/2025 05:39	1/24/2025 14:39	70333159014	Lead	<1.0	5	ug/L
107A Cafeteria Bubbler	1/14/2025 05:28	1/24/2025 14:41	70333159015	Lead	<1.0	5	ug/L
107B Cafeteria Bottle Fill	1/14/2025 05:29	1/24/2025 14:45	70333159016	Lead	<1.0	5	ug/L
108 Kitchen Ice Machine	1/14/2025 05:18	1/24/2025 14:47	70333159017	Lead	<1.0	5	ug/L
109 Kitchen Sink	1/14/2025 05:19	1/24/2025 14:49	70333159018	Lead	1.4	5	ug/L
110 Kitchen Sink	1/14/2025 05:20	1/24/2025 14:53	70333159019	Lead	5.8	5	ug/L
112 Kitchen Steam Oven	1/14/2025 05:23	1/24/2025 14:58	70333159021	Lead	2.6	5	ug/L
115A Hallway Bubbler	1/14/2025 05:11	1/24/2025 15:05	70333159022	Lead	<1.0	5	ug/L
115B Hallway Bottle Fill	1/14/2025 05:12	1/24/2025 15:07	70333159023	Lead	<1.0	5	ug/L
126 Distirct office Sink	1/14/2025 05:26	1/24/2025 15:08	70333159024	Lead	2.2	5	ug/L
132A 2nd Floor Bubbler	1/14/2025 05:14	1/24/2025 15:10	70333159025	Lead	<1.0	5	ug/L
132B 2nd Floor Bottle Fill	1/14/2025 05:15	1/24/2025 15:12	70333159026	Lead	<1.0	5	ug/L
134 Nurse Bathroom Sink	1/14/2025 05:55	1/24/2025 15:13	70333159027	Lead	<1.0	5	ug/L
135 Nurse Sink	1/14/2025 05:54	1/24/2025 15:15	70333159028	Lead	<1.0	5	ug/L
136 Faculty Room Sink	1/14/2025 05:56	1/24/2025 15:16	70333159029	Lead	<1.0	5	ug/L
109 Kitchen Sink	1/14/2025 05:20	1/24/2025 15:18	70333159030	Lead	1.1	5	ug/L

Remedy

Date Remedy was Completed

Date Re tested

Replace Faucet and Re test Removed Faucet 1/29/2025 - Ordered New Faucet.

NYSDOH Action Level for Lead in Schools of 5 ppb